



Network Status
Normal



System Status
Normal



Energy Storage Inverter



2023-10-25 11:02:19

Current Power: ● No data.

Plant O&M:

 Settings

 Transfer Plant

 Advanced Settings

 Delete

Advanced Settings X

ESS Advanced Config

ESS Safety Config

Name	Value	Unit	Range
<input type="checkbox"/> HM ESS Safety	DE_VDE4105	-	-
Safety			
Safety Nominal Voltage	230	V	230~230
Safety Nominal Frequency	50	Hz	50~50

Wenn das **Export-Soft-Limit-Verhältnis auf 0 %** eingestellt ist, wird standardmäßig kein Strom an das Netz übertragen.

Active Power Control (APC)			
Generation Control Function (GCF)			
GCF Function Code	1000		1~1
Function Activated	<input type="text" value="Enable"/>	-	-
Export Soft Limit Ratio	<input type="text" value="16"/>	%	0~200